

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-1501:137 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: *Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

DESIGN: Models 1501, A1501, 1502, 1504, 1505, 1508, and 1509, door holders with or without suffixes AQ, N5, EI, GI, E5, GT, or D-GT. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as fire-rated door holders. When used on fire-rated doors an approved closer shall be used.

NOTE: Formerly 3550-1388:100, 3550-0073:040, 3550-0789:118, 3550-0999:101

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager